



Getting Started with CHP:

Initial Screening and Air Permitting

January 29, 2015

Lissa McCracken

Acting Director

KPPC

Cheryl Eakle, CEM

Sustainability Engineer

KPPC

Sreenivas Kesaraju, PE

Engineering Consultant

Kentucky Division for Air Quality

CHP Partners



U.S. DEPARTMENT OF ENERGY
CHP Technical Assistance Partnerships
SOUTHEAST



**KENTUCKY ASSOCIATION
OF MANUFACTURERS**



KPPC

Kentucky's Resource Center for
Environmental Sustainability




Before we start...

- **Today's webinar is being recorded and will be available at the KPPC website.**
- **All participants are muted to prevent feedback.**
- **We will be accepting questions through the question and answer portion of your control panel.**
- **Feel free to type questions as we present.**
- **We will address questions at the end of each presentation.**

More Housekeeping

How to Participate Today



The screenshot displays the GoToWebinar application window. The 'Audio' panel is at the top, showing 'Audio Mode' with 'Use Telephone' selected. Below it are the dial-in details: 'Dial: 213-286-1201', 'Access Code: 616-522-718', and 'Audio PIN: 72'. A note states: 'If you're already on the call, press #72# now.' Below the Audio panel is the 'Questions' panel, which is highlighted with a red border. It contains a text input field with the placeholder '[Enter a question for staff]' and a 'Send' button. At the bottom of the window, there is a banner for 'Start Holding your Own Web Events with GoToWebinar' and 'Webinar ID: 977-124-241'.

- Open and close your Panel
- Submit text questions

CITRIX online



Initial Screening for CHP

Cheryl Eakle, CEM
Sustainability Engineer
KPPC


What is Combined Heat and Power?

CHP is an *integrated energy system* that:

- Is located at or near a factory or building
- Generates electrical and/or mechanical power
- Recovers waste heat for
 - heating,
 - cooling or
 - dehumidification
- Can utilize a variety of technologies and fuels



Conventional CHP




Separate Energy Delivery:

- Electric generation – 33%
- Thermal generation - 80%
- Combined efficiency – 45% to 55%

CHP Energy Efficiency (combined heat and power)
70% to 85%




Waste Heat to Power



- Fuel first applied to produce useful thermal energy for the process
- Waste heat is utilized to produce electricity and possibly additional thermal energy for the process
- Simultaneous generation of heat and electricity
- Normally produces larger amounts electric generation (*often exports electricity to the grid; base load electric power*)

CHP Project Development



CHP Initial Screening



Kentucky CHP TAP Qualification Screening

Reciprocating Gas CHP System - no power export from site

Facility Information

| | |
|--------------------------------------|-----------------|
| Facility Name | Hospital |
| Location (City, State) | Somewhere, KY |
| Application | In-Patient Care |
| Annual Hours of Operation | 8760 |
| Annual Electricity Consumption (kWh) | 16,061,600 |
| Average Power Demand (MW) | 1.83 |
| Annual Fuel Consumption (MMBtu) | 53,953.00 |
| Annual Thermal Demand (MMBtu) | 43,162.4 |
| Average Thermal Demand (MMBtu/hr) | 4.9 |

2012-2013 Actual Fuel Consumption times ~ 80% efficiency

| | |
|------------------------------------|---------|
| Average Electricity Costs (\$/kWh) | \$0.065 |
| Thermal Fuel Costs (\$/MMBtu) | \$5.030 |
| CHP Fuel Costs (\$/MMBtu) | \$5.030 |
| Percent Electric Price Avoided | 80% |

2012-2013 Average Electricity cost

2012-2013 Average Fuel cost

CHP System

| | |
|----------------------------------|---------|
| Net CHP Power (MW) | 1.20 |
| CHP Electric Efficiency, % (HHV) | 38.0% |
| CHP Thermal Output (Btu/kWh) | 4,260 |
| CHP Power to Heat Ratio | 0.80 |
| CHP Availability (%) | 95% |
| Incremental O&M Costs (\$/kWh) | \$0.010 |
| Displaced Thermal Efficiency (%) | 80.0% |
| Thermal Utilization (%) | 100.0% |

Calculated based on CHP power output and thermal output
90 to 98%

Displaced onsite thermal (boiler, heater, etc) efficiency
Amount of available thermal captured and used - typically 80 to 100

| | |
|---|---|
| Stand-by Electric Required? (1=Yes, 0=No) | 0 |
| Required Standby Capacity (kW) | |
| Standby Charge (\$/kW) | |



Considerations--Electricity

- **Use base load if known (kW)**
- **Otherwise**
$$\frac{\text{Annual electric use (kWh)}}{\text{Annual hours of operation}}$$
- **Use “effective” cost of electricity**
$$\frac{\text{Annual electric cost (\$)}}{\text{Annual electric use (kWh)}}$$
- **Sub-meter information for partial facility**

Considerations--Thermal

- Need year-round thermal demand
- Use base load if known (MMBtu/hr)
- Otherwise
$$\frac{\text{Annual thermal load (MMBtu)}}{\text{Annual hours of operation}}$$

CHP Initial Screening



CHP TAP CHP Qualification Screen

Boiler/Steam Turbine (backpressure) CHP

Facility Information

| | | |
|-------------------------------------|-----------------------|--------------------------|
| Facility Name | Auto Parts, Inc. | |
| Location (City, State) | Kentucky | |
| Application | Automotive Components | |
| Annual Hours of Operation | 8400 | Annual operating hours w |
| Average Power Demand, MW | 6 | 6.8 |
| Annual Electricity Consumption, kWh | 57,000,000 | |
| Average Steam Demand, MMBtu/hr | 7.2 | |
| Annual Steam Demand, MMBtu | 60,480 | |
| Current Fuel Costs, \$/MMBtu | \$5.79 | |
| CHP Boiler Fuel Costs, \$MM/Btu | \$5.79 | |
| Effective Electricity Costs, \$/kWh | \$0.077 | |
| Percent Electric Price Avoided | 90% | Typically 70 to 95% |

CHP System

| | | |
|--|---------|----------------------------|
| New Boiler = 1; Steam Turbine Only = 0 | 0 | |
| CHP Availability, % | 98% | Steam Turbine availability |
| Boiler Thermal Efficiency, % | 80.0% | May need to modify for b |
| CHP Power to Heat Ratio | 0.09 | CHP System Specs 2 - use |
| Net CHP Power, MW | 0.2 | Based on typical power tc |
| CHP Electric Efficiency, % (HHV) | 7.2% | Typically between 5 to 20 |
| CHP Thermal Output, Btu/kWh | 37,944 | |
| Steam Turbine O&M Costs, \$/kWh | \$0.010 | CHP system specs - includ |



CHP Initial Screening

Annual Energy Consumption

Base Case

| | |
|----------------------------|------------|
| Generated Electricity, kWh | 0 |
| Purchased Electricity, kWh | 57,000,000 |
| Boiler Steam, MMBtu | 60,480 |
| CHP Boiler Steam, MMBtu | 0 |
| Boiler Fuel, MMBtu | 75,600 |
| CHP Boiler Fuel, MMBtu | 0 |
| Total Fuel, MMBtu | 75,600 |

CHP Case

| | |
|----------------------------|------------|
| Generated Electricity, kWh | 1,562,031 |
| Purchased Electricity, kWh | 55,437,969 |
| Boiler Steam, MMBtu | 0 |
| CHP Boiler Steam, MMBtu | 60,480 |
| Boiler Fuel, MMBtu | 0 |
| CHP Boiler Fuel, MMBtu | 82,398 |
| Total Fuel, MMBtu | 82,398 |

Simple Payback

Annual Operating Savings, \$
Total Installed Costs, \$/kW
Total Installed Costs, \$
Simple Payback, Years

| |
|-----------|
| \$53,268 |
| \$1,000 |
| \$189,751 |
| 3.6 |

Stand-by Costs

Stand-by Power Needed (yes=1, no=0)
Stand-by Demand Required (kW)
Stand-by Rate (\$/kW)
Administration Charge (\$/month)
Total Stand-by Costs (\$)

| |
|--------|
| 0 |
| |
| |
| |
| \$0.00 |

Operating Costs to Generate

Fuel Costs, \$/kWh
Thermal Credit, \$/kWh
Incremental O&M, \$/kWh

| |
|-----------|
| \$0.305 |
| (\$0.280) |
| \$0.010 |
| |
| \$0.035 |

Annual Operating Costs

Purchased Electricity, \$
Standby Power, \$
On-site Thermal Fuel, \$
CHP Fuel, \$
Incremental O&M, \$
Total Operating Costs, \$

| |
|-------------|
| \$4,389,000 |
| \$0 |
| \$437,724 |
| \$0 |
| \$0 |
| \$4,826,724 |

| |
|-------------|
| \$4,280,751 |
| \$0 |
| \$0 |
| \$477,085 |
| \$15,620 |
| \$4,773,456 |


Total Operating Costs to Generate, \$/kWh



Stand-by Rates

- **Stand-by rates can affect operating cost/savings**
- **Considerations**
 - Monthly charge or contract (\$3.56-\$12.86/kW)
 - Ratchet
 - Administrative charge
- **Work with utility**
- **Minimize stand-by charges**
 - Only use/contract for essential operations
 - Design system to shed loads for CHP outage
 - Use production shut-downs for maintenance

Illustration of a Self-Generator's Purchase Requirements



4

Courtesy of the Regulatory Assistance Project (RAP) and Brubaker and Associates

Conclusion

- **CHP is efficient use of energy**
- **Contact KPPC for free screening**
 - Need base loads (electric and thermal)
 - Effective costs (electric and fuel)
 - Consider stand-by costs
- **KPPC can do initial Feasibility Analysis (also at no cost)**



QUESTIONS?

Initial Screening for CHP

Cheryl Eakle, CEM

cheryl.eakle@louisville.edu

(502) 852-3485

www.kppc.org




Air Quality Permitting Requirements for CHP Processes

Sreenivas Kesaraju, P.E.

Engineering Consultant

Kentucky Division for Air Quality

Typical CHP Process



Air Quality Permit to Construct and Operate

- **A Permit is a stand-alone document that includes regulatory requirements applicable to each of the sources emission units. In Kentucky the permit issued is a construction/operating permit that gives the source authority to construct and operate.**
- **The permit:**
 - **identifies emission units to be regulated,**
 - **establishes emission/operating limits to be met,**
 - **outlines procedures including: Testing, Record keeping, Monitoring and Reporting requirements to maintain continuous compliance with the limits.**

Kentucky's Permitting/Registration Thresholds

- **Abbreviations:**

- PTE means potential to emit, i.e., the maximum amount of a pollutant that a source is physically capable of emitting, or is legally allowed to emit, whichever is less
- HAP means hazardous air pollutant
- RAP means regulated air pollutant other than a HAP
- AR means applicable requirement
- MOC means method of compliance
- NSPS means New Source Performance Standard
- NESHAP means National Emission Standard for Hazardous Air Pollutants, and includes MACT/NESHAPS

When is a Permit Required?

- **Construct and Operate a new source**
 - Major source (Title V)
 - Synthetic minor source or Conditional Major source
 - Federal Enforceable State Operating Permit (FESOP)
 - Minor source
 - Registration only (small source)
- **Modify an existing source**
- **Renew an existing source**
- **"Source" means one (1) or more affected facilities contained within a given contiguous property line. "Affected facility" means an apparatus, building, operation, road, or other entity or series of entities that emits or may emit an air contaminant into the outdoor atmosphere.**

Kentucky's Permitting/Registration Thresholds

- **Nothing is required (no registration or permit) if a source's PTE is:**
 - <2 tpy of a HAP;
 - <5 tpy of combined HAPs;
 - <10 tpy of a RAP; and
 - The source is not subject to a NSPS or NESHAP
- **Registration is required if a source's PTE is:**
 - > 2 but < 10 tpy of a HAP
 - > 5 but < 25 of combined HAPs;
 - > 10 but < 25 tpy of a RAP subject to an AR that does not specify the MOC;
 - or
 - If the source is subject to a NSPS or NESHAP.

Kentucky's Permitting/Registration Thresholds

- **A state origin permit is required if a source's PTE is:**
 - < 10 tpy of a HAP;
 - < 25 tpy of combined HAPs; and
 - > 25 but <100 tpy of a RAP.
- **A Title V permit is required if a source's PTE is:**
 - > 10 tpy of a HAP;
 - > 25 tpy of combined HAPs; or
 - > 100 tpy of a RAP; and
 - The source's PTE is not limited below these thresholds by a permit (conditional major) or prohibitory rule.

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky rules or federal rules.

PROJECT DESCRIPTION

- **XYZ campus (new under construction campus) is planning to construct CHP system to generate 10 MW of energy and 110,000 pounds of steam**
- **They found a natural gas turbine that can generate 8 MW of power and the Heat Recovery steam generator (HRSG) will produce 35000 pounds of steam. The turbine fuel input required is 80 mmBTU/hr.**
- **They decided to use this system with some changes to the CHP system and their plan.**
- **They decided to buy additional 2 MW they need from the grid.**
- **They decided to use 40 mmBTU/hr natural gas duct firing before the HRSG to give them additional 75,000 pounds of steam.**

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT

- **To implement this plan an air permit from Kentucky Division for Air Quality (KDAQ) is needed.**
- **The source (permittee) needs the following data to submit an application to KDAQ**
 - 1. Engineering design of the affected units with information such as maximum design rate (units that generate air emissions).
 - 2. Emission Estimate for all the regulated air pollutants emitted from each affected unit within the source.
 - 3. Using emission estimates, figure out what kind of permit is required (use above thresholds given).
 - 4. What application forms and other documents need to be submitted?

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 1. Maximum Design Rate


- Engineering design of the affected units (units that generate air emissions) will give information such as maximum design rate
- Engineering design includes data such as what is the maximum hourly raw material input needed for the equipment to work
- In this case study, Affected Units: 1. Turbine, 2. Duct Burner
- Note: the HRSG does not produce any air emissions. It recovers heat and produces steam. The units above are the only emission generating activities.
- Maximum Design Rates:
 - 1. Turbine → 80 mmBTU/hr fuel input (manufacturer's rating)
 - 2. Duct Burner → 40 mmBTU/hr fuel input (manufacturer's rating)

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

Turbine – Setup

courtesy - Google images by www.interelectra.com and www.turbine-diesel.ru



Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 2. Emission Estimates

- Emissions shall be estimated for all the regulated air pollutants emitted from each affected unit within the source.
- The emissions estimates should be the “Potential emissions” for each affected unit.
- “Potential to emit” or “PTE” means the maximum capacity of a stationary source to emit a pollutant under its physical and operational design.
- **PTE = Maximum hourly design rate X Emission factor X 8760 hr/yr**
- For our case study, emission factors used are from manufacturer’s data. There is also a compilation of emission factors at www.epa.gov/ttn/chief/ap42. When a unit is purchased the manufacturers generally provide emission guarantees. These emission factors can be used in PTE calculations, but Division has the authority to follow with Testing Requirements in the permit to verify these numbers.
- The hours per year used will always be 8760 hr/yr unless the source willingly takes permitted limits (called “voluntary limits”). If you want to take voluntary limits, you need to get a federally enforceable permit.
- For our case study we will estimate emissions for two different turbine configurations available with two different emission guarantees for NO_x, CO and VOC. Better emission guarantee will be higher capital expenditure.

AIR QUALITY PERMIT – 2. Emission Estimates

| TURBINE Emission Factors | Turbine 1 | | | Turbine 2 | | |
|------------------------------------|-----------------|--------------|--------------|-----------------|--------------|--------------|
| | NO _x | CO | VOC | NO _x | CO | VOC |
| Ib/MMBtu | 0.06 | 0.061 | 0.035 | 0.1 | 0.121 | 0.035 |
| DUCT BURNER Emission Factors | | | | | | |
| | NO _x | CO | VOC | NO _x | CO | VOC |
| Ib/MMBtu | 0.065 | 0.04 | 0.05 | 0.065 | 0.04 | 0.05 |
| PTE in Tons per year | | | | | | |
| | NO _x | CO | VOC | NO _x | CO | VOC |
| For TURBINE | 21.02 | 21.37 | 12.26 | 35.04 | 42.4 | 12.26 |
| For DUCT BURNER | 11.39 | 7.01 | 8.76 | 11.39 | 7.01 | 8.76 |
| TOTAL ANNUAL PTE | 32.42 | 28.38 | 21.02 | 46.43 | 49.41 | 21.02 |

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 3. WHAT PERMIT DO I NEED

- Based on information from above slide, the source-wide emissions of all estimated regulated air pollutants (RAP) from this project are above 25 TPY but below 100 TPY.
- This will require a STATE ORIGIN PERMIT and will be regulated under 401 KAR 52:040, State Origin permits.

Division for Air Quality
200 Fair Oaks Lane, 1st Floor
Frankfort, Kentucky 40601
(502) 564-3999
AIR QUALITY PERMIT
Issued under 401 KAR 52:040

| | |
|-------------------------|--|
| <u>Permittee Name:</u> | XYZ Campus |
| <u>Mailing Address:</u> | 123 Main Street, Suite 1, <u>Hoginville</u> , TX 32217 |
| <u>Source Name:</u> | Frankfort Campus, Kentucky Division |
| <u>Mailing Address:</u> | <u>1234 S. Brooke St.</u> Frankfort, KY 40601 |
| <u>Source Location:</u> | Corner of Brooke and Oak Streets |
| <u>Permit:</u> | <u>S-15-973</u> |

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 4. Application Forms and Other Documents

- Any construction activity emitting air pollution needs to get prior approval (permit, or Registration) from state of Kentucky. The application forms that need to be submitted will depend on if you need a permit or a registration.
- The application forms are listed on the Division website at www.air.ky.gov
- The forms are listed as a series starting from DEP7007A Form through DEP7007Y Form for permit related forms and DEP7039A form for a Minor source Registration applications.
- The form DEP7007AI form is the administrative information form listing the source information. Rest of the forms in the series require process, emissions, stack and compliance information from the source.
- DEP7007A form for example is the form for Indirect Heat Exchanger, Turbine, Internal Combustion Engine.
- For this project this would be one of the important forms to fill.

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 4. Application Forms and Other Documents

- The forms are mostly in Word format and are fillable. The forms generally followed by Instructions to fill.

Program : Permitting (32)

CAIR Permit
Application



CAIR Permit Application

DEP7007A Form



DEP7007A Indirect Heat Exchanger, Turbine, Internal
Combustion Engine

DEP7007AA Form



DEP7007AA Compliance Schedule for Noncomplying
Emission Units

DEP7007AA
Instructions



DEP7007AA Compliance Schedule For Non-Complying
Emission Units

DEP7007 AI Form



DEP7007AI Administrative Information

DEP7007B
Instructions



DEP7007B Manufacturing and Processing Operations

DEP7007B Form



DEP7007B Manufacturing or Processing Operations

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 4. Application Forms and Other Documents

- The DEP 7007A form is used to list the details of the Turbine. See the DEP7007A form example below:

| | |
|---|--|
| 2) Type of Unit (Make, Model, Etc.): Combustion Turbine (Caterpillar xyz) without Duct burner – Simple cycle operation | |
| Date Installed: <u>December 2014 (estimated)</u> | Cost of Unit: _____ |
| (Date unit was installed, modified or reconstructed, whichever is later.) | |
| Where more than one unit is present, identify with Company's identification or code for this unit: | |
| Combustion Turbine (CT)) – Emission Point 1 | |
| 2a) Kind of Unit (Check one): | 2b) Rated Capacity: (Refer to manufacture's specifications) |
| 5. Indirect Heat Exchanger _____ | 1. Fuel input (mmBTU/hr): NG: 80 (HHV) @ 59 deg Fahrenheit |
| 6. Gas Turbine for Electricity Generation <u>X</u> | 2. Power output (hp): _____ |
| 7. Pipe Line Compressor Engines: | Power output (MW): NG: 8 MW @ 59 deg Fahrenheit [1] |
| _____ Gas Turbine | |
| _____ Reciprocating engines | |
| (d) 2-cycle lean burn _____ | |
| (e) 4-cycle lean burn _____ | |
| (f) 4-cycle rich burn _____ | |
| 8. Industrial Engine _____ | |
| [1] Plant Gross Generation | |
| SECTION I. FUEL | |
| 3) Type of Primary Fuel (Check): | |
| _____ A. Coal | B. Fuel Oil: # (Check one) <u>1</u> <u>2</u> <u>3</u> <u>4</u> <u>5</u> <u>6</u> |
| <u>X</u> C. Natural Gas | _____ D. Propane _____ E. Butane _____ F. Wood _____ G. Gasoline |
| _____ H. Diesel | I. Other (specify) _____ |
| 4) Secondary Fuel (if any, specify type): _____ | |

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 4. Application Forms and Other Documents

- The DEP7007V form is used to list the applicable requirements and compliance activities. See the example below:

SECTION I. EMISSION AND OPERATING STANDARD(S) AND LIMITATION(S)

| KYEIS No. ⁽¹⁾ | Emission Unit Description ⁽²⁾ | Contaminant ⁽³⁾ | Origin of Requirement or Standard ⁽⁴⁾ | Applicable Requirement, Standard, Restriction, Limitation, or Exemption ⁽⁵⁾ | Method of Determining Compliance with the Emission and Operating Requirement(s) ⁽⁶⁾ |
|--------------------------|--|----------------------------|--|--|--|
| 098 099 100 | Combustion Turbine - Simple Cycle | NOX | 40 CFR 60 Subpart KKKK | Natural Gas Emission Limit: 15 ppm at 15 percent O ₂ | Vendor guarantees meet these limits. |
| | | SO ₂ | 40 CFR 60 Subpart KKKK | Fuel Emission Limit: 0.06 lb SO ₂ / 10 ⁶ Btu | Fuel analysis indicates 0.06 lb SO ₂ / 10 ⁶ Btu will not be exceeded |

SECTION II. MONITORING REQUIREMENTS

| KYEIS No. ⁽¹⁾ | Emission Unit Description ⁽²⁾ | Contaminant ⁽³⁾ | Origin of Requirement or Standard ⁽⁴⁾ | Parameter Monitored ⁽⁷⁾ | Description of Monitoring ⁽⁸⁾ |
|--------------------------|--|----------------------------|--|------------------------------------|--|
| 098 099 100 | Combustion Turbine - Simple Cycle | NOX | 40 CFR 60 Subpart KKKK | NOX | Continuous Emissions Monitoring System for each combustion turbine |

SECTION III. RECORDKEEPING REQUIREMENTS

| KYEIS No. ⁽¹⁾ | Emission Unit Description ⁽²⁾ | Contaminant ⁽³⁾ | Origin of Requirement or Standard ⁽⁴⁾ | Parameter Recorded ⁽⁹⁾ | Description of Recordkeeping ⁽¹⁰⁾ |
|--------------------------|--|----------------------------|--|--|--|
| 098 099 100 | Combustion Turbine - Simple Cycle | N/A | 40 CFR 60.7(b) | Start-ups, shutdowns, and malfunctions | Maintain records of these events. |

Sample sheet only. Not related to the example project above.

SECTION IV. REPORTING REQUIREMENTS

| KYEIS No. ⁽¹⁾ | Emission Unit Description ⁽²⁾ | Contaminant ⁽³⁾ | Origin of Requirement or Standard ⁽⁴⁾ | Parameter Reported ⁽¹¹⁾ | Description of Reporting ⁽¹²⁾ |
|--------------------------|--|----------------------------|--|---|--|
| 098 099 100 | Combustion Turbine - Simple Cycle | N/A | 40 CFR 60 Subpart KKKK | See Table 3-2 of main document for requirements | |
| | | | 40 CFR 63 Subpart YYYY | See Table 3-7 of main document for requirements | |

SECTION V. TESTING REQUIREMENTS

| KYEIS No. ⁽¹⁾ | Emission Unit Description ⁽²⁾ | Contaminant ⁽³⁾ | Origin of Requirement or Standard ⁽⁴⁾ | Parameter Tested ⁽¹³⁾ | Description of Testing ⁽¹⁴⁾ |
|--------------------------|--|----------------------------|--|---|--|
| 098 099 100 | Combustion Turbine - Simple Cycle | CO, NOX, SO ₂ | 40 CFR 60.8(a) | Performance test of combustion turbines | Performance testing must occur within 60 days after achieving maximum production rate but no later than 180 days after initial start-up. |

Kentucky's Permitting – CHP Case Study

This case example is presented as a working exercise to facilitate discussion and is not intended to offer any formal or official interpretation of the Kentucky permitting rules.

AIR QUALITY PERMIT – 4. Application Forms and Other Documents

- The permittee can contact the Division for assistance on the forms or any other permit related questions. See the contact information on Division's website.
- The DEP7007N form is used to submit the emissions and stack information. See an example below:

| SECTION I. Emission Units and Emission Point Information (continued) | | | | | | | | | | | |
|--|------------------|--------------------------------|-----------------------|-------------------------------|----------------------------------|----------------------------------|------------------------------|-----------|----------------------------------|------------------------------|-----------|
| KyEIS ID # | Emission Factors | | | Control Equipment | | Hourly (lb/CT-hr) Emissions | | | Annual (tons/CT-yr) Emissions | | |
| | Pollutant | Emission Factor (lb/SCC Units) | Emission Factor Basis | Control Equipment Association | Pollutant Overall Efficiency (%) | Uncontrolled Unlimited Potential | Controlled Limited Potential | Allowable | Uncontrolled Unlimited Potential | Controlled Limited Potential | Allowable |
| Sample sheet only. Not related to the example project above. | | | | | | | | | | | |
| 101 | Filter. PM | 4.03E-03 | Vendor Data | 1st control device | Low-NOX | 9.00 | 9.00 | | 39.4 | 18.6 | |
| or | Filter. PM10 | 4.03E-03 | AP-42, Ch. 3.2 | KyEIS Control ID #: | 01 | 9.00 | 9.00 | | 39.4 | 18.6 | |
| 102 | Filter. PM2.5 | 4.03E-03 | AP-42, Ch. 3.2 | Collection efficiency: | | 9.00 | 9.00 | | 39.4 | 18.6 | |
| or | Cond. PM | 4.03E-03 | Eng. Estimate | | | 9.00 | 9.00 | | 39.4 | 18.6 | |
| 103 | SO2 | 1.92E-03 | Eng. Estimate | 2nd control device | CatOx* | 4.28 | 4.28 | | 18.7 | 8.83 | |
| | NOX | 7.23E-03 | Vendor Data | KyEIS Control ID #: | 02 | 161 | 16.1 | | 706 | 33.3 | |
| | CO | 5.50E-03 | Vendor Data | Collection efficiency: | 70% | 40.9 | 12.3 | | 179 | 25.3 | |
| | VOC | 1.89E-03 | Vendor Data | | 30% | 6.02 | 4.22 | | 26.4 | 8.71 | |
| | H2SO4 | 1.71E-05 | Eng. Estimate | 3rd control device | SCR | 0.0382 | 0.0382 | | 0.167 | 0.0788 | |
| | CO2 equiv. | 1.17E+02 | 40 CFR Part 98 | KyEIS Control ID #: | 03 | 261,246 | 261,246 | | 1,144,257 | 539,473 | |
| | Lead | 4.00E-07 | EPRI's EFH* | Collection efficiency: | 70% | 8.92E-04 | 8.92E-04 | | 3.91E-03 | 1.84E-03 | |
| | Total HAP | 4.57E-04 | AP-42 & EFH** | | | 1.020 | 1.020 | | 4.47 | 2.11 | |



QUESTIONS?

**Air Quality Permitting Requirements
for
CHP Processes**

SREENIVAS KESARAJU
sreenivas.kesaraju@ky.gov
(502) 564-3999

www.air.ky.gov

Resources

- **KPPC**
www.kppc.org
- **Division for Air Quality**
www.air.ky.gov
- **DEDI**
<http://energy.ky.gov/Programs/Pages/chp.aspx>
- **DOE**
www.doe.gov or www.energy.gov
- **Southeast CHP Technical Assistance Partnership**
www.southeastchptap.org/



Resources

- **Association of Energy Engineers**

www.aeecenter.org



www.energystar.gov/

Wrap-Up

- **Webinar Recording**
www.kppc.org
- **Upcoming Event**
 - Site Visit & Demonstration – March 2015
- **Webinar Survey**